



Type test Certificate of Complete Type Test

Shenzhen Woer Heat-Shrinkable Material Co., Ltd

Shenzhen, China

has successfully passed the type test sequence on a

cold shrinkable indoor termination

Type: 15 kV cold shrink indoor 3 core

Rating: 8,7/15 (17,5) kV

The test object passed the specification of test duties of

IEC 60502-4

The test results are recorded in Certificate No.

07-1015

This Certificate is issued on 6 November 2007

KEMA Nederland B.V.

P.G.A. Bus
KEMA T&D Testing Services
Managing Director

Copyright © KEMA Nederland B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has certified or approved any apparatus other than the specimen tested.

Experience you can trust.